





Key Plan
Scale : 1:5000



Proposed Watermain Layout
Scale : 1:500

Legend:

Watermain Details:		Document No. IW-CDS-5020-01	
88	Denotes Connection Pipe (25mm O.D. PE Pipe)	Water Service Connection Responsibility :	STD-W-01
		Customer Connection & Boundary Box :	STD-W-03
88	Denotes Connection Pipe (32mm O.D. PE Pipe)	Marker Posts & Plates :	STD-W-27
	Denotes 110/125mm O.D. HDPE Watermain	General Pipe Connections :	STD-W-04
	Denotes 110/125mm O.D. HDPE Watermain loop	General Pipe Connections :	STD-W-05
		General Pipe Connections :	STD-W-07
	Denotes 150mm O.D. HDPE Watermain	Trench Backfill and Bedding :	STD-W-13
		Watermain Thrust & Support Blocks :	STD-W-28
SV001	Denotes Sluice Valve	Sluice Valve :	STD-W-15
		Marker Posts & Plates :	STD-W-27
WO	Denotes Washout Hydrant	Washout Hydrant :	STD-W-30A
NRV	Denotes Non-Return Valve	On Line Hydrant :	STD-W-18
FH003	Denotes Fire Hydrant	Off Line Hydrant :	STD-W-19
		Marker Posts & Plates :	STD-W-27
AV001	Denotes Air Valve	Air Valve :	STD-W-22
Meter Chamber	Denotes Water Meter	Meter Chamber :	STD-W-26/26A
		Marker Posts & Plates :	STD-W-27
ExWM	Denotes Existing Public Watermain		

Note: Refer to Irish Water Standard Details Drawings Document No. IW-CDS-5020-01

1. Mains should extend no more than 1.2m beyond the final Service Connection to mitigate dead-end Mains (Code of Practice for Water Infrastructure - Section 3.5)
2. Service connection pipes should be a minimum of 25mm ouside diameter, 20mm inside diameter, and should be provided with appropriately sized fittings. (Code of Practice for Water Infrastructure - Section 3.8)
3. Separation distances must be in compliance with Standard details & Code of Practice for Water Infrastructure
4. All meters in the manifold shall be tagged to indicate which property is supplied and any unused outlets are to be blanked off.

DOSA
DENIS O'SULLIVAN & ASSOCIATES
CONSULTING ENGINEERS

Joyce House
Barrack Square
Ballincollig
Cork
P31 KP84

021 4871781
info@dosa.ie
www.dosa.ie

© THIS DRAWING IS COPYRIGHT. NO PART OF THIS DOCUMENT MAY BE RE-PRODUCED OR TRANSMITTED IN ANY FORM OR STORED IN ANY RETRIEVAL SYSTEM OF ANY NATURE WITHOUT THE WRITTEN PERMISSION OF THE ENGINEER AS COPYRIGHT HOLDER EXCEPT AS AGREED FOR USE ON THE PROJECT FOR WHICH THE DOCUMENT WAS ORIGINALLY ISSUED.

REV.	DRAWN	CHKD	APPRVD	DATE	DETAILS
F	D.O'S.	S.O'G.	L.O'T.	27.04.'26	Issued For Planning

CLIENT: Dipharma Unlimited Company.

PROJECT: Development at Countess Road, Killarney, Co. Kerry

DRAWING TITLE: Proposed Watermain Layout Plans (2 of 2)

SHEET: A1

SCALE: 1:500

PROJECT NO. 7334 _ DRAWING NO. 0031 _ STATUS/ISSUE F